

DECLARATION OF CONFORMITY UNDER THE SPECIFICATION ISO/IEC 22 GUIDE

Manufacturer : **EBRILLE SRL**

Adress: **S.S. Nizza-Canelli 53/A – 14049 Nizza Monferrato (AT) – Italy -**

Product : **EBRILSPLIT CE**

Application field: **air conditioning and refrigeration**

Declares that the product “EBRILSPLIT” complies following regulations

Employed copper : the mechanical, chemical and dimensional features of our copper tubes used for **EBRILSPLIT CE** are complying to the following regulation :

Norm/document No.	Title	Edition/Date of issue
UNI EN 12735-1	Round copper tubes for air conditioning and refrigeration	2010

According to the above mentioned elements, the copper tubes of our product **EBRILSPLIT CE** are suitable for the passage of gas R410/A, R407/C.


Employed insulation coating : the mechanical and dimensional features of the product **EBRILSPLIT CE** are complying to the following specification :

UNI EN 14313	Thermal insulation products for building equipment and industrial installations	2009 + A1: 2013
--------------	---	-----------------

Being the product **EBRILSPLIT CE** in compliance with the annex ZA of the above mentioned norm and re to the system 1, it has been classified as a building equipment and associate the **CERTIFICATE OF CONSTANCY OF PERFORMANCES N° 0497/CPR/5119 in compliance with the regulation 305 /2011/EU, regulation concerning the construction products or CPR**

Employed insulation coating : the physical-chemical and dimensional features of the product **EBRILSPLIT CE** are in compliance with:

Law, decree or regulation/document no.	Title	Edition/Date of issue
Rule of 9 th January 1991, no. 10	Specifications for the application of the National Energy efficiency Plan concerning the rational use of energy, the energy saving and the development of the renewable resources.	1991
By law of 19 th August 2005, no. 192	Application of the directive 2002/91/CE for the energy efficiency in the buildings	2005
By law of 29 th December 2006, no. 311	Corrective and additional measures by law 19 August 2005, no. 192, with implementation of Directive 2002/91/CE, referring to the energy efficiency in the buildings	2006



Concerning the fire reaction class, the insulation foam employed for the insulated copper pipes **EBRILSPLIT CE** complies to :

The European norm EN 13501-1 : 2007 “ Fire reaction class of the building products and elements “ having obtained the class B₁s1 d0

The value of **thermal conductivity λ 0.038 W * m⁻¹ * K⁻¹ a 40 °C** of the insulation complies to his employment under the specification ISO 8497

The value of **permeability to water steam $\mu \geq 12.000$** of the insulation complies to his employment under the EN 13469.

The thermal/heating resistance of the PE insulation allows to employ it with operating temperatures between **- 45 °C and + 110°C up to peaks of 120 °C.**

All the conformities above mentioned are subordinated to the respect of the specifications in force as per Law N° 46:1990, and D.M 37/2008 and UNI EN 378:2009.

The present declaration is released for the uses allowed from the law.

Nizza Monferrato, January 2015